

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:169 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Model Multi-Net Manager proprietary and central station receiving unit. Refer to listee's data sheet for detailed product description and operational considerations. System components:

UWS-586P	Unlisted Component Computer
PCLTA-10	Communication Board
WSSUP	Watchdog Supervisory Board
SoundBlaster 16	Audio Board
3C509B-Combo	Ethernet Crad
QM33240STA	Hard Drive
C4423/CD532E	CD ROM
PRN-4	Printer
Flashpoint 128PLI	Communication Board
PLI8R	Digi-Board
N/A	Monitor (Any monitor listed for fire protective signaling)

RATING: 120 VAC, 2A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a proprietary and central station receiving unit for use with listee's separately listed compatible fire alarm control units.

NOTE: Formerly 7300-0085:185

XLF: 7300-1525:100

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**